Rapid news number: RNPI24-004
Date: 13/12/2023
From: DENV Residential Application SBU
Pages: 3

1.Content:

Clarification on adapters for Comfora (N and N9) and Sensira (E)

Rapid news number: RNPI24-004
Date: 13/12/2023
From: DENV Residential Application SBU
Pages: 3

Dear Madam,
Dear Sir,

We would like to take the occasion to clarify the difference between the two options available as interface adaptor for wired remote controller for Comfora and Sensira.

In Daikin's option portfolio we have the following two:

Material name	Product Name
KRP980A1	KRP980B1
KRP067A41	EKRP067A419

They are both composed by a S21 PCB and a cable for connection to indoor unit and they are used for the very same function: allow connection with wired remote controller and they work as interface adapter for many other options.
The only difference between the two option is that while KRP067A41 is made by S21 port and cable only, the KRP980A1 also has a casing to contain them both. Still, the casing itself is not useful to scope of installation and it has to be removed before mounting the adapter in the unit.

KRP067A41



KRP980A1



As the availability may change depending on the option, we strongly advise to check them both before ordering. As today (January 24) we advise to purchase KRP067 as there is availability of this option.

Currently, for split portfolio, the are used for the following products

- For Comfora
  - FTXP 20/25/35 - N
  - ATXP 20/25/35 - N
  - FTXP 20/25/35 - N9
  - ATXP 20/25/35 – N9

- For Sensira
  - FTXF 20/25/35/42 - E
  - ATXF 20/25/35/42 – E

Also, we invite you to consult the data books (in option list chapter) of the products above for a comprehensive overview and explanations of options.